


1 MAINTENANCE BLDG. POWER PLAN
SCALE: 1/8" = 1'-0"

2 ONE-LINE DIAGRAM
N.T.S.

KEYED NOTES: (THIS SHEET ONLY)

- 1 CONTRACTOR SHALL PROVIDE, INSTALL, AND CONNECT COMPLETE CLASS A FIRE ALARM SYSTEM TO MEET ALL LOCAL AND BASE CODES.
- 2 CONTRACTOR SHALL PROVIDE, INSTALL, AND CONNECT ALL WIRING, CONDUIT ETC IN THIS AREA IN ACCORDANCE WITH THE N.E.C. REQUIREMENTS FOR A CLASS I DIVISION 2 HAZARDOUS LOCATION.
- 3 CONTRACTOR SHALL PROVIDE, INSTALL, AND CONNECT ALL WIRING, CONDUIT ETC IN THIS AREA IN ACCORDANCE WITH THE N.E.C. REQUIREMENTS FOR A CLASS II DIVISION 2 HAZARDOUS LOCATION.



SYMBOL		DESCRIPTION	DATE
REVISIONS			
Drawn by: G. CRAWL		HEADQUARTERS AIR FORCE SERVICES AGENCY	
COORDINATION:		Title:	
Engr:		UNITED STATES AIR FORCE	
Design and Construction:		NON-APPROPRIATED FUNDS PROJECT	
APPROVAL:		35% AFNAF PROTOTYPES DESIGN	
Director of Facilities		CONTRACT NO. NAFA196C0002	
date		GOLF COURSE COMPLEX. -	
Director of Operations		POWER PLAN	
date		SCALE: 1/8" = 1'-0"	SHEET
		DATE: APRIL 7, 2000	E102
		DRAWING NUMBER:	OF